

USN

--	--	--	--	--	--	--	--	--	--

10EE71

**Seventh Semester B.E. Degree Examination, Feb./Mar. 2022**  
**Computer Techniques in Power System Analysis**

Time: 3 hrs.

Max. Marks: 100

**Note: Answer any FIVE full questions, selecting atleast TWO questions from each part.**

**PART – A**

- 1 a. With an explain and neat sketch explain the following :  
 i) Oriented graph ii) Tree iii) Co-tree iv) Tree branch path incidence matrix. (10 Marks)
- b. For the network graph shown below, consider elements 1, 2, 3 as tree branches and node as reference and obtain :  
 i) Bus incidence matrix  
 ii) Branch path incidence matrix. There from show that  $A_b K^T = I$ .




Fig.Q2(b)

(10 Marks)

- 2 a. For the system line data given below, obtain the  $Y_{BUS}$  by singular transformation select bus 6 as reference bus and a tree with elements 6 and 7 as links. Verify the results obtained by the methods of inspection.

Line no.	1	2	3	4	5	6	7
Bus code p-q	1-6	2-6	2-5	1-3	3-4	4-5	3-6
Admittance in pu	30	45	20	10	25	15	35

(10 Marks)

- b. Find  $Z_{BUS}$  for the system whose reactance diagram is shown below : All the impedances are marked in p.u.




Fig.Q2(b)

1 of 2

(10 Marks)

Important Note : 1. On completing your answers, compulsorily draw diagonal cross lines on the remaining blank pages.  
 2. Any revealing of identification, appeal to evaluator and/or equations written eg, 42+8 = 50, will be treated as malpractice.

- 3 a. Explain the algorithm of Gauss Seidel Load Flow method for a power system having all types of buses. (10 Marks)
- b. Following is the data of power system for load flow solution.

BUS codes	Line Data Admittance
1 - 2	$2 - 8j$
1 - 3	$1 - 4j$
2 - 3	$0.666 - 2.664j$
2 - 4	$1 - 4j$
3 - 4	$2 - 8j$

BUS Data

BUS code	P	Q	V	Remarks
1	-	-	1.06	Slack
2	0.5	0	$1.04 + j0$	PV
3	0.4	0.3	-	PQ
4	0.3	0.1	-	PQ

Reactive power constraint at bus 2 is  $0.1 \leq Q_2 \leq 1.0$  p.u. Determine the voltage at the end of first iteration using Gauss – Seidel method. Assume acceleration factor  $\alpha = 1.6$ . (10 Marks)

- 4 a. Explain with the help of algorithm the computational procedure for load flow solution using NR method, when the system is containing all types of buses. (10 Marks)
- b. Compare Newton Raphson method, Gauss Seidel iterative method. (06 Marks)
- c. Mention the approximations made FDLF method for load flow analysis. (04 Marks)

## PART – B

- 5 a. Explain the method of equal incremental costs for the economic operation with the transmission losses considered. (10 Marks)
- b. Two generators are coupled through a tie line. Load is at the bus of generator 2, it is known that a transfers of 100MW from generator 1 over the tie line means a transmission loss of 10WM. The incremental costs are
- $$\frac{df_1}{dP_1} = 0.02P_1 + 16 \quad \frac{dF_2}{dP_2} = 0.04P_2 + 20$$
- Find the optimum schedule, total generation and demand if  $\lambda = 25$ Rs/Mwh. (10 Marks)
- 6 a. What are transmission loss coefficients obtain the general expression of  $B_{mn}$  with usual notations. (10 Marks)
- b. Explain the mathematical formulation and solution procedure of optimal scheduling of hydro-thermal plants. (10 Marks)
- 7 a. Explain various methods employed for improving the transient stability. (10 Marks)
- b. Explain method of finding the transient stability of a given power system using Milne's predictor corrector method. (10 Marks)
- 8 a. Consider the system having following parameters :
- $P_m = 3.0$ pu ;  $\gamma_1 P_m = 1.2$ pu ;  $v_2 P_m = 2.0$ ,  $H = 3.0$  ;  $f = 60$ Hz,  $\Delta t = 0.02$ sec,  $p_e = 1.5$ pu. Determine rotor angle and angular frequency at the end of 0.2 seconds using modified Euler's method. (10 Marks)
- b. Explain the representation the following for power system stability studies
- i) Exciters (Type 1 system) ii) Governors. (10 Marks)

\*\*\*\*\*